



CB TEST CERTIFICATE

Ref. Certificate No.

CH-5163-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: Electrosuisse

Product: Switches and signal indicators Emergency stop device with mechanical latching

Applicant: EAO AG Tannwaldstrasse 88 Switzerland
Postfach
CH-4601 Olten

Manufacturer: EAO AG Tannwaldstrasse 88 Switzerland
Postfach
CH-4601 Olten

Factory: EAO AG Tannwaldstrasse 88 Switzerland
Postfach
CH-4601 Olten

Rating and principal characteristics: Ue max: 500VAC, 110VDC, Ith max: 10A; IP65
(for details see test reports)

Trade mark (if any): eao

Model/Type reference: Series 04; Part no. 704.xxx.x
(for details see test reports)

Additional information: This CBTC replaces certificate CH-5163-M1 due to new screwless terminals. Basic certificate CH-5163 issued 2009-03-06

Sample of product tested to be in conformity with IEC: 60947-5-1(ed.3);am1
60947-5-5(ed.1);am1

National differences:
EU Group Differences

Test Report Ref. No.: 02-IK-0359.02 + .03 + .06 + .07

This CB Test Certificate is issued by the National Certification Body:

Electrosuisse
Luppmenstrasse 1,
CH-8320 Fehraltorf

Signed by: Erich Obrist
2010-07-21

electrosuisse 